


NOTES:

1. ALL MATERIALS AND INSTALLATION SHALL BE IN ACCORDANCE WITH FAYPWC STANDARDS.
2. ALL DUCTILE IRON PIPE SHALL HAVE AN INTERIOR LINING OF CERAMIC EPOXY (PROTECTO 401) OR APPROVED EQUAL.
3. ALL BELOW GRADE FITTINGS SHALL BE MECHANICAL JOINT WITH RETAINING GLAND JOINT RESTRAINT (IE: MEGA-LUGS).



CONCRETE BOLLARD DETAIL

FORCE MAIN BY-PASS PUMPING ASSEMBLY N.T.S.			FAYETTEVILLE PUBLIC WORKS COMMISSION FAYETTEVILLE, N.C.			NO.	DATE	REVISION
SHEET NO. 1 OF 1	DWG. NO. S.21	DWG. BY: FAYPWC	WATER RESOURCES ENGINEERING DEPARTMENT					
	DATE: JAN. 01, 2025	APPROVED BY: K.A.H.						